

STRADA AUREL VLAICU

STRADA NOUA



LEGENDA

- BMPT Bloc masura protectie trifazic
- TEG Tablou electric general proiectat
- Linie electrica subterana cablu CYAbY
- Priza de pamant OL-Zn 40x4 mm
- Electrode OL-Zn D= 2/1/2" l=3.0m
- Piesa de separatie
- Corp iluminat tip spot incastrat exterior contur biserica si turnuri, echipat cu lampa HOLOPAR 30 de 75 w
- Corp iluminat tip spot incastrat exterior contur zid echipat cu 5 leduri de 1w alb

pavaj- marcare a pozitiei zidului de fortificatie a cetatii

Scoala



Biserica

Turnul Fierarilor

Turnul Cizmarilor

Turnul Croitorilor

Scoala



- 4 CYAbY 3 x 2,5 mmp
- CYAbY 3 x 35 + 16 mmp
- 6 CYAbY 3 x 2,5 mmp
- 2 CYAbY 3 x 4 mmp
- 1 CYAbY 3 x 2,5 mmp
- 5 CYAbY 3 x 1,5 mmp
- OL - Zn 40x4 mm
- 3 CYAbY 3 x 4 mmp

VERIFICATOR	NUME	SEMNTURA	SEMNTURA	REFERAT NR./DATA
PROVIDO P.F.A. F32/1693/2004 SIBIU, Bd. Victoriei, nr. 35 Tel/Fax 0269/214286, Tel 0766/416498				Beneficiar: PAROHIA EVANGHELICA C.A. AGNITA Proiect 18/2016
SPECIFICATIE	NUME	SEMNTAT	SCARA	Faza DT-AC
Proiectat	ing V. Poclitaru		Sc. 1:250	Titlu proiect: REABILITAREA ANSAMBLULUI BISERICII EVANGHELICE FORTIFICATE AGNITA - PIATA G.D. TEUTSCH NR 1-3
Proiectat	ing V. Poclitaru		Data 02/2018	Titlu plansa: PLAN DE SITUATIE Retele electrice Iluminat exterior Priza de pamant Plansa Nr. EO.01